



INTERNATIONAL JOURNAL OF CREATIVE RESEARCH THOUGHTS (IJCRT)

An International Open Access, Peer-reviewed, Refereed Journal

Fault Detection In IEEE 9 Bus System Using Matlab & Simulink

¹Kiruthika K, ²Vishal G, ³Vivek N, ⁴Bhumika K Ramesh, ⁵Jyoti

¹Assistant Professor, ²UG Student, ³UG Student, ⁴UG Student, ⁵UG Student

¹¹Department of Electrical & Electronics Engineering

¹Rajarajeswari college of Engineering, Bengaluru, India

Abstract: This project presents a fault detection methodology for the IEEE 9-bus system using MATLAB and Simulink. The IEEE 9-bus system is a well-established testbed for studying power system stability and fault analysis due to its complexity and interconnectivity. In this study, various types of faults, including single-line-to-ground (SLG), line-to-line (LL), double-line-to-ground (DLG), and three-phase faults, are simulated and analyzed. The primary objective is to develop a fault detection mechanism that accurately identifies and classifies fault types, location, and severity within the network. The system dynamics are modeled using MATLAB's Simulink environment, leveraging the capabilities of the Sim Power Systems toolbox for power systems simulation. The proposed fault detection algorithm employs wavelet transforms and signal processing techniques to analyze the transient response during fault conditions. By examining voltage and current waveforms at critical nodes, the algorithm pinpoint's fault locations and classify fault types based on characteristic transient features. The findings of this research are essential for advancing the reliability of protection systems, as the early detection of faults minimizes system downtime and ensures stable power delivery. The project concludes with a performance analysis of the fault detection approach, illustrating its effectiveness and accuracy across different fault scenarios in the IEEE 9-bus model.

Index Terms -Fault Detection, IEEE 9-Bus System, Wavelet Transform

I. INTRODUCTION

The reliability and stability of a power system are crucial for ensuring uninterrupted power delivery. Faults in power systems, such as short circuits or line-to-ground faults, can cause severe disruptions, leading to equipment damage, power outages, and economic losses. Hence, the need for accurate and efficient fault detection methods is paramount.

The IEEE 9-bus system is a standard benchmark model widely used in power system studies. It represents a simplified yet realistic configuration of a power grid, encompassing generators, transmission lines, and load buses. This system serves as an ideal platform for analyzing various operational and fault scenarios due to its manageable complexity and representational accuracy.

Using MATLAB and Simulink for fault detection in the IEEE 9-bus system enables researchers and engineers to model, simulate, and analyze power system behavior under normal and fault conditions. MATLAB provides a versatile programming environment, while Simulink offers a graphical interface for dynamic system simulation. Together, they allow for:

Modeling of Power System Components: Accurate representation of generators, transformers, transmission lines, and loads.

Fault Simulation: Creation of various fault conditions, such as single-line-to-ground (SLG), double-line-to-ground (DLG), line-to-line (LL), and three-phase faults.

Fault Detection Mechanisms: Implementation of algorithms to identify fault types, locations, and severity based on voltage, current, and power measurements.

System Response Analysis: Evaluation of how the power system responds to faults, aiding in the design of protective relays and control strategies.

This project aims to develop a robust fault detection framework for the IEEE 9-bus system. By leveraging MATLAB & Simulink, it seeks to enhance understanding of fault dynamics and contributes to improved fault management in modern power systems.

II. BLOCK DIAGRAM




Fig. Block Diagram of Fault Detection in IEEE 9 Bus System Using Matlab & Simulink

This block diagram illustrates a fault detection system for an IEEE 9 bus power system using MATLAB and Simulink. The system begins with a 230V AC power supply that feeds into a rectifier for AC to DC conversion. The converted power then flows through transmission lines, which form the core component where potential faults may occur. The transmission lines connect to multiple monitoring and control components. A voltage and current indicator monitor the electrical parameters, while an Arduino UNO microcontroller processes this information and controls the system's response. The Arduino manages a relay that can connect or disconnect the load based on detected conditions, and it displays relevant system information through an OLED display.

The fault detection module continuously monitors the transmission lines for any abnormalities or faults in the power system. When a fault is detected, the system can respond by triggering the relay to protect the load. This setup enables real-time monitoring, fault detection, and protective actions in the power distribution system, with the Arduino serving as the central control unit that processes inputs and manages outputs based on the system's conditions. The entire system represents a practical implementation of power system protection, combining hardware components with MATLAB and Simulink software for simulation and control purposes. This integration allows for both theoretical analysis and practical demonstration of fault detection in power systems.

III. CIRCUIT DIAGRAM




Fig. Circuit Diagram of Fault Detection in 2 Bus System

The system consists of two Arduino Uno boards working together to control and monitor eight AC light lines through relay modules. Each Arduino manages four relay modules, with Arduino Uno 1 controlling relays 1-4 and Arduino Uno 2 controlling relays 5-8. The setup is powered by a 9V DC supply derived from AC power through a rectifier circuit. Each Arduino board is equipped with an OLED display connected via I2C protocol (using pins A4 and A5) to show real-time voltage and current measurements of the monitored lines.

The core functionality revolves around power monitoring and protection. The system continuously monitors voltage (through pins A0-A3) and current (through pins A4-A7) for each line, comparing them against preset thresholds (10V for voltage and 2A for current). If voltage drops too low or current exceeds the safe limit, the corresponding relay switches off automatically, and the system activates the next relay in sequence. Each relay module connects to an AC light holder using a Normally Open (NO) configuration for the live wire and Common (COM) for the neutral wire, ensuring safe switching and electrical isolation between the control circuit and AC power lines.

IV. METHODOLOGY

The methodology for implementing this fault detection system begins with the installation of voltage and current sensors along the transmission lines of the IEEE 9 bus system. These sensors continuously monitor the electrical parameters in real-time, feeding this data to the Arduino Uno microcontroller for processing. The Arduino is programmed to analyze these inputs against predetermined threshold values that indicate normal operating conditions. When deviations occur, the system triggers appropriate responses through its output devices. The installation phase also includes setting up OLED displays for data visualization and configuring LED indicators for quick status checks, while the relay component is integrated to provide protective isolation capabilities when necessary.

During operation, the system follows a sequential process where sensor readings are sampled at regular intervals by the Arduino. The collected data undergoes algorithmic analysis to detect any anomalies such as overcurrent, undervoltage, or phase imbalances. Upon detecting a fault condition, the system initiates several simultaneous actions: it activates relevant LED indicators, updates the OLED displays with fault information and electrical parameters, and can trigger the relay to disconnect the load if necessary. This comprehensive monitoring approach utilizes dual OLED displays - one for fault-specific information and another for real-time voltage/current measurements - ensuring operators have complete visibility into system status while maintaining protective functions through automated relay responses when fault conditions are detected.

IV. RESULTS AND DISCUSSION

4.1 Software Results




Fig. IEEE 9 BUS SYSTEM

This image represents a single-line diagram of the IEEE 9-bus system modeled in a simulation environment such as MATLAB/Simulink. The diagram includes various components of a power system: generators, transformers, transmission lines, loads, and buses. The system operates at different voltage levels, including 230 kV, 220 kV, 16.5 kV, and 13.8 kV, with the use of transformers for voltage regulation. It incorporates load flow data, represented by arrows showing power (MW and MVAR) and per-unit voltages with phase angles at each bus. Reactive power compensation devices are connected to maintain voltage stability. The model includes fault simulation capabilities, highlighted by a three-phase fault on one of the lines. The layout demonstrates the interaction of generators, loads, and transmission lines to analyze stability, fault detection, or power flow distribution.




Fig. Voltage Characteristics Of The Line – Ground Fault

This graph illustrates the voltage characteristics of a power system under a line-to-ground fault condition. The waveform shows the system's voltage behavior over time, with a noticeable disturbance occurring at the fault instant, typically around 0.1 seconds. Before the fault, the voltages are stable and sinusoidal. At the fault occurrence, a sharp drop or fluctuation is observed, followed by transient oscillations. These oscillations eventually dampen as the system stabilizes, depending on the protection scheme and system damping characteristics. The graph effectively captures the dynamic response of the voltage to a fault, making it useful for analyzing the system's transient stability and fault-clearing mechanisms.




Fig. Current Characteristics of the Line – Ground Fault

The line-to-ground fault characteristics shown in the graph display a distinctive pattern of system response during a fault event. The most prominent feature is a significant initial disturbance, indicated by high-amplitude oscillations in the red waveform, followed by a period of damped oscillations across multiple traces (shown in red, blue, and cyan). These traces, which likely represent different electrical parameters such as phase currents or voltages, demonstrate how the system responds to and attempts to stabilize after the fault occurrence. The waveforms eventually settle into a steady-state condition after the initial transient period, with all traces converging to more stable values, illustrating the power system's natural response and potential protective measures taking effect during the fault condition.




Fig. Voltage Characteristics Of The Double Line – Ground Fault

The plot illustrates the voltage characteristics of a double line-to-ground fault in an IEEE 9-bus system, highlighting the system's transient and steady-state behavior. A sharp spike at the onset indicates the transient response caused by the sudden imbalance in voltages due to the fault. This is followed by a stabilization phase where the voltages return to a steady state, reflecting the system's ability to recover from the disturbance. Such analysis is critical for understanding fault dynamics and designing effective protection schemes




Fig. Current Characteristics Of The Double Line – Ground Fault

This plot depicts the current characteristics of a double line-to-ground fault in an IEEE 9-bus system, showing both transient and steady-state responses. At the onset of the fault, the system exhibits sharp spikes in current due to the sudden disturbance and imbalance caused by the fault. Following this transient phase, the currents gradually settle into oscillations with a lower amplitude, indicating the system's stabilization and recovery. Such characteristics are vital for analyzing fault impacts and optimizing protection mechanisms in power systems.




Fig. Current Characteristics Of The Line-Line – Ground Fault

This plot shows the current characteristics of a line-to-line ground fault in an IEEE 9-bus system. The waveform exhibits periodic oscillations, indicating the fault's impact on the system currents. The oscillatory nature reflects the dynamic response of the system under fault conditions, highlighting variations in the current magnitudes across phases. Such analysis is crucial for understanding the behavior of the power system during faults and designing appropriate protective measures to ensure system stability and reliability.

4.2 Hardware Results




Fig. Hardware Result

This model represents fault detection in a 2-bus power system. It includes poles symbolizing transmission lines, sensors to measure electrical parameters, and digital displays showing voltage or current levels for each bus. The system is designed to identify faults, such as voltage drops or line failures, and visually display the affected parameters. The project demonstrates the operation of fault detection and response mechanisms in a simplified and educational framework, simulating real-world scenarios in power systems.

V. CONCLUSION

Fault detection in an IEEE 9-bus system using MATLAB & Simulink involves simulating various fault scenarios and analyzing their impacts on the power system. By integrating power system analysis with advanced control techniques, MATLAB & Simulink offer a robust platform for evaluating system performance under fault conditions. Through detailed simulations, it becomes possible to identify the type and location of faults, assess the system's stability, and develop corrective actions to mitigate the impact of faults. This helps in improving the reliability and efficiency of power systems by ensuring prompt fault detection and reducing downtime.

Additionally, utilizing MATLAB & Simulink for fault detection provides a comprehensive understanding of system behavior under different fault conditions. The integration of simulation tools enables engineers to test various protection schemes, evaluate their effectiveness, and optimize system parameters. This process ultimately contributes to enhancing the overall performance of the power system, ensuring a more resilient and secure electricity supply for consumers.

REFERENCES

- [1] Prof. Faisal Mumtaz, Hardware Supported Fault Detection and Localization Method for AC Microgrids Using Mathematical Morphology with State Observer Algorithm, 21 November 2023, IEEE
- [2] Prof. Xin Li, Analysis and design of connection between solar farm and IEEE 9 bus system, 2021, IEEE
- [3] Zhihua Li, Zhanfei Yang, Chunhua Wu, Simulation of Fault Detection in Photovoltaic System Based On SSTDR, 2020, IEEE
- [4] Aditya Patel, M.V.S. Prashant, Jharna Sahu, Ancy Prerena Kujur, Protection Scheme based on Fault Detection and Fault Classification using Fuzzy inference system in IEEE-9 Bus System, 2018, IEEE
- [5] Frank Gerdinand, Johann Meisner, Stephan Passon, PSCAD/EMTDC-based Simulations for Fault Analysis and Fault Identification in 380V Ring DC Systems, 2017, IEEE
- [6] Sajjadi M, Seifi H, A new Approach for Parameter Estimation of Power System Equipment Models, 9-11 Dec 2019, Piscataway, NJ, USA, IEEE, 2019
- [7] Shekar M C, Aarthi N, Contingency Analysis of IEEE 9 Bus System, 18-19 May 2018, IEEE International Conference on Recent Trends in Electronics, Information & Communication Technology, 2018
- [8] <https://www.midalcable.com/sites/default/files/AAC-metric.PDF>
- [9] Kaur R, Kumar D, Transient Stability Improvement of IEEE 9 Bus System Using Power World Simulator, 18-19 March 2016, France, EDP Sciences, 2016
- [10] Kaur R, Kumar D, Transient Stability Improvement of IEEE 9 Bus System Using Power World Simulator, 18-19 March 2016, France, EDP Sciences, 2016
- [11] https://www.pscad.com/uploads/knowledge_base/ieee_9_bus_technical_note.pdf
- [12] A. Cagnano, E. De Tuglie, P. Mancarella, MicroGrids: Overview and guidelines for practical implementations and operation, Appl. Energy, vol. 258, Jan. 2020, IEEE, 2020
- [13] N. Hussain, M. Nasir, J. C. Vasquez, J. M. Guerrero, Recent developments and challenges on AC microgrids fault detection and protection systems—A review, Energies, vol. 13, no. 9, p. 2149, May 2020, IEEE, 2020

- [14] H. R. Baghaee, D. Mlakic, S. Nikolovski, T. Dragicevic, Support vector machine-based islanding and grid fault detection in active distribution networks, IEEE J. Emerg. Sel. Topics Power Electron., vol. 8, no. 3, Sep. 2020, IEEE, 2020
- [15] R. Tiwari, R. K. Singh, N. K. Choudhary, Coordination of dual setting overcurrent relays in microgrid with optimally determined relay characteristics for dual operating modes, Protection Control Modern Power Syst., vol. 7, no. 1, Dec. 2022, IEEE, 2022

